

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

HELENA JUBANY
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

E. FELICIA BRANNON
VICTOR H. CUEVAS
SEPAND SAMZADEH

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
SUPERINTENDENT OF BUILDING
INTERIM GENERAL MANAGER

AVM Industries, LLC
8245 Remmet Avenue
Canoga Park, CA 91304

Attn: Amir Rudyan
(818) 888-0050

RESEARCH REPORT: RR 25431
(CSI # 09 30 00)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR-2662

Expires: December 1, 2015
Issued Date: October 1, 2013
Code: 2011 LABC

GENERAL APPROVAL – Reevaluation-AVM System 700 Waterproof Membrane.

DETAILS

The above assemblies and/or products is approved when in compliance with the description, use, identification and findings of Report No. ESR-2662 reissued March 1, 2012 of the ICC Evaluation Service, Incorporated. The Report, in its entirety, is attached and made part of this general approval.

The parts of Report No. ESR-2662 marked by the asterisks have been removed by the Los Angeles Building Department from this approval.

The approval is subject to the following conditions:

1. Store all materials at temperatures between 50°F and 90°F. Do not store materials in direct sunlight or where they may be damaged by water or rain. Bags must be kept dry.
2. The materials for the system shall be delivered to the jobsite in sealed containers identified by the manufacturer's name product name and shelf life.
3. Installation of AVM System 700 shall be in accordance with the manufacturer's instructions, a copy of which shall be available at each jobsite.
4. Surfaces to be covered shall be sound, clean and free of laitance, oil, wax or grease. Cement substrates shall be troweled semi smooth or finished with light broom surface texture.

RR 25431
Page 1 of 2

- 5 After the membrane has cured, carefully inspect the surface for bubbles blotches, clumps or other imperfections at the fabric joints or within the field areas.
6. The coating system shall not be applied at temperatures below 40° F

DISCUSSION

The report is in compliance with the 2011 Los Angeles City Building Code.

The approval is based on tests in accordance with the ICC-ES Acceptance Criteria for Waterproof Membrane used as ceramic Tile Underlayment (AC115), dated June 2003 (editorially revised September 2011).

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

ALLEN PEERY, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

RJG
RR25431 /MSWord2010
R09/27/13
4E/1501/1505.1

Attachment: ICC ES Report No. ESR-2662 (2 Pages)