

# CITY OF LOS ANGELES

CALIFORNIA

BOARD OF  
**BUILDING AND SAFETY**  
COMMISSIONERS

—  
VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
**BUILDING AND SAFETY**  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

—  
FRANK M. BUSH  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

—  
Simpson Strong-Tie Co., Inc.  
12246 Holly St.  
Riverside, CA 92509

Attn: Jason Oakley, P.E.  
(714) 448-9143

RESEARCH REPORT: RR 25744  
(CSI # 03 16 00)

BASED UPON ICC ES EVALUATION  
REPORT NO. ESR-2508

REEVALUATION DUE  
DATE: December 1, 2018  
Issued Date: January 1, 2018  
Code: 2017 LABC

**GENERAL APPROVAL** – Reevaluation - SET-XP Epoxy Adhesive Anchors for Cracked and Uncracked Concrete

## **DETAILS**

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, conditions of approval, evidence, and identification of Report No. ESR-2508, reissued July 1, 2017, revised July 10, 2017, of the ICC Evaluation Service, LLC. The report, in its entirety, is attached and made part of this general approval.

The parts of Report No. ESR-2508 which are marked by the asterisks are deleted or revised by the Los Angeles City Building Department from this approval.

### **The approval is subject to the following conditions:**

1. The design information listed in the attached report and tables are valid for the fasteners only. Connected members shall be checked for their capacity (which may govern).
2. The anchors shall be identified by labels on the packaging indicating the manufacturer's name and product designation.
3. Design information, edge distances, spacing and minimum embedment requirements shall be per Tables in ICC-ES Report No. ESR-2508.

RR 25744  
Page 1 of 3

Simpson Strong-Tie

RE: SET-XP Epoxy Adhesive Anchors for Cracked and Uncracked Concrete.

4. Special inspection in accordance with Section 1705.3 of the 2017 Los Angeles City Building Code shall be provided for anchor installations.
5. The anchors shall be installed as per the attached manufacturer's instructions except as otherwise stated in this report. Copies of the installation instructions shall be available at each job site.
6. The adhesive anchors shall not be used to support fire-resistive construction, unless in compliance with Section 5.13 of ICC-ES Report No. ESR-2508.
7. Minimum concrete cover per Chapter 25 of the ACI 318-14 shall be followed whenever applicable.
8. Attachment to masonry is outside the scope of this approval.

## **DISCUSSION**

The clerical modification is to update the report to the 2017 City of Los Angeles Building Code.

The report is in compliance with the 2017 City of Los Angeles Building Code.

This approval is based on ICC-ES Acceptance Criteria for Post-Installed Adhesive Anchors in Concrete (AC308), dated January 2016.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

Simpson Strong-Tie

RE: SET-XP Epoxy Adhesive Anchors for Cracked and Uncracked Concrete.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Simpson offers software to assist in the design of anchorage using Simpson products

---

QUAN NGHIEM, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9812  
Fax- 213-202-9943

DE  
RR25744  
R12/24/17  
TLB1700425  
1912, ACI 318-08 Ch. 17

Attachment: ICC ES Report No. ESR-2508 (18 Pages)