BOARD OF BUILDING AND SAFETY COMMISSIONERS

VAN AMBATIELOS PRESIDENT

E. FELICIA BRANNON VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL GEORGE HOVAGUIMIAN JAVIER NUNEZ

> Crossfield Products Corporation 3000 East Harcourt Street Rancho Dominguez, CA 90221

Attn: Steven Schroeder (310) 886-9100 (310) 722-7842 CITY OF LOS ANGELES



DEPARTMENT OF BUILDING AND SAFETY 201 NORTH FIGUEROA STREET LOS ANGELES, CA 90012

OSAMA YOUNAN, P.E. GENERAL MANAGER

ERIC GARCETTI MAYOR

RESEARCH REPORT: RR 2360 (CSI #07180)

Expires:July 1, 2022Issued Date:July 1, 2020Code:2020 LABC

GENERAL APPROVAL - Renewal and Clerical Modification - Crossfield Products Corporation Surfacing Materials

- 1. Dex-O-Tex weatherwear as a Class A fire-retardant roof covering over wood, concrete and steel roof decks. For wood decks, Dex-O-Tex is applied over ³/₄" exterior grade wood structural panel, or over ¹/₂" exterior grade wood structural panel over one inch sheathing.
- 2. Dex-O-Tex Décor Flor as floor covering in toilet rooms.
- 3. Dex-O-Cote and Dex-O-Cote WB and Wallcote E. Wallcote W, and Flex Glaze as finishes for walls and ceilings of food preparation and toilet rooms.
- 4. Dex-O-Tex Cheminert as floor covering in food establishments and toilet rooms.
- 5. Dex-O-Tex Neotex 261as floor covering in food establishments and toilet rooms.
- 6. Dex-O-Tex Decorflor as floor covering in food establishments and toilet rooms.
- 7. Dex-O-Tex Kwik-Flor as floor covering in food preparation and toilet rooms provided approval is secured for each job from the County of Los Angeles Department of Health Services.
- 8. Dex-O-Tex Post-Tred as floor covering in food preparation area provided approval is secured for each job from the County of Los Angeles Department of Health Services.

RR 2360 Page 1 of 4 Crossfield Products Corporation

RE: Crossfield Products Corporation Surfacing Materials

- 9. Dex-O-Tex A-81 Underlayment is synthetic cementitious copolymer for smoothing or filling rough or porous substrates.
- 10. Dex-O-Tex Neobond Fracture-Resistant Waterproof Membrane is a composite system consisting of a proprietary Neoprene rubber emulsion waterproofing membrane with a fabric reinforced cementitious protection layer.

Fire-Retardant Class A Roof Assembly is as follows:

- 1. Roof deck is wood structural panel installed with a maximum slope of ¹/₂ inch per horizontal foot. Wood structural panel joints are filled with joint treatment consisting of one part N-38 paste to three parts grout powder, mixed by weight. Total thickness is 9/32 inch minimum.
- 2. One layer of ConGlass, ConBase Type W1 asphalt-coated fiberglass base sheet is laid over the plywood terminating 2" from perimeter. The sheets are 36 inches wide by 36 yards long, weigh 74.5 pounds/324 square feet and are lapped 2 inches each way. The sheets comply with ASTM D2178 as Type IV.
- 3. Neobond IITM or Barrier GuardTM is mixed and troweled onto the base sheet. Coverage is 28 pounds per square.
- 4. Loose woven polypropylene, nominal 0.035 inch thick, weighing 7 ounces per square yard is embedded into the wet Neobond IITM mixture. The fabric is supplied in rolls 40 inches wide by 300 feet or 360 feet long and adjacent runs are lapped 2 inches each way. The combined dry thickness of Neobond IITM and fabric is 0.070 inch. This combination is allowed to reach a dry state (3 to 4 hours).
- 5. An additional application of Neobond IITM is used to fill voids in the jute fabric. The Neobond IITM is mixed as noted in Item 2 and is applied at a rate of 21 pounds per square, yielding a 0.025 inch dry thickness. The total Neobond IITM application is 46 pounds per square, or 0.0905 inch dry thickness.
- 6. After the Neobond II[™] has cured to a dry state, (6 hours minimum), a mixture of one part N-38 paste and 5 parts Standard Neotex powder, by weight, is applied. Application is at a rate of 80 pounds per square, yielding a 0.090 inch dry thickness. After curing to a dry state (12 hours minimum), a second application is made at a rate of 52 pounds per square, yielding a 0.060 inch dry thickness. Total application is 132 pounds per square, for a 0.150 inch dry thickness.
- 7. After the Standard Neotex has cured to a dry state (12 hours minimum), a standard topping mixture, consisting of one part N-38 paste and two parts standard topping powder, by weight, is troweled on at a rate of 17.5 pounds per square, yielding a 0.015 inch dry thickness. After curing to a dry state (4 hours), a second application is made at a rate of 11.5 pounds per square, for a 0.010 inch dry thickness. Total application is 29 pounds per square, for a 0.025 inch dry thickness.

Crossfield Products Corporation

RE: Crossfield Products Corporation Surfacing Materials

8. After the standard topping mixture has cured to a dry state (4 hours), two coats of AJ-44A dressing are roller applied, yielding a total coverage of two squares per gallon, for a 0.005 inch dry thickness. The first coat must achieve a dry cure of 4 hours, prior to the application of the second coat.

Total thickness of items (excluding base sheet) 2 through 7 is 0.2660 inches.

Application of the surface materials shall be in conformance with the manufacturer's specifications. The minimum thickness of floor and roof Dex-O-Tex coverings is 3/16".

When applied over a wood floor, the substrate shall be minimum $\frac{3}{4}$ " wood structural panel nailed to joists spaced maximum 16" o.c. with annular ring shank or screw type nails. When applied over a roof deck, the substrate may be $\frac{3}{4}$ " wood structural panel or $\frac{1}{2}$ " wood structural panel over one inch sheathing. Wood structural panel joints are filled with joint treatment consisting of one part N-38 paste to three parts grout powder.

DISCUSSION

The clerical modification is to update this report to the 2020 LABC.

The report is in compliance with 2020 Los Angeles Building Code.

Test data are on file with the Engineering Research Section.

Wallcote E. Wallcote W, and Flex Glaze is a wall covering for food establishments and for public rest room areas. It is a two component modified resin over wall of poured concrete, wood structural panel or steel. It has an ASTM E-84 flame spread of 15 and a smoke factor of 15. This material is acceptable to the Health Department. Its formula is on file with the Department.

Dex-O-Cote is a compounded vinyl resin which is trowel or spray applied as a finish coating.

Dex-O-Tex Neotex 261 is a latex mastic compound comprised of elastomers. These elastomers are blended with cementitious material and a 90% or above silica content aggregate.

Dex-O-Tex Decorflor is a two component resin matrix with mineral aggregates.

Dex-O-Tex Kwik-Flor is a ¹/₄" thick monolithic flooring consisting of two component resinous system with aggregates and filler.

Dex-O-Tex Posi-Tred is a slip resistant two component resinous system with skid-resistant aggregates. The material is trowelled on. Thicknesses range from 15 to 52 mils. Slip resistance for handicap compliance shall be determined by the Disabled Access Section in accordance with MGD #80.

RE: Crossfield Products Corporation Surfacing Materials

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, <u>complete with any attachments indicated</u>, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

DAVID CHANG, Chief Engineering Research Section 201 N. Figueroa St., Room 880 Los Angeles, CA 90012 Phone - 213-202-9812 Fax - 213-202-9943

DC RR2360/MSWord2013 R08/21/2020 TLB2000135 104.2.6

> RR 2360 Page 4 of 4