

**BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS**

VAN AMBATIELOS  
PRESIDENT

JAVIER NUNEZ  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
ELVIN W. MOON

**CITY OF LOS ANGELES**  
CALIFORNIA



ERIC GARCETTI  
MAYOR

**DEPARTMENT OF  
BUILDING AND SAFETY**  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

**OSAMA YOUNAN, P.E.**  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

**JOHN WEIGHT**  
EXECUTIVE OFFICER

Tremco, Incorporated  
3735 Green Road  
Beachwood, OH 44122

Attn: Wes Hensley  
(216) 766- 5531

**RESEARCH REPORT: RR 25299**  
(CSI #07140)

Expires May 01, 2024  
Issued Date: October 11, 2021  
Code: 2020 LABC

**GENERAL APPROVAL** – Renewal - Tremproof 6100 Membrane for below grade waterproofing

**DETAILS**

Tremproof 6100 Membrane is hot applied rubberized asphalt specially formulated from asphalts, rubber and inert fillers. The minimum thickness of the installed products is 180 mil.

**The approval is subject to the following conditions:**

1. Installation of the product shall be in accordance with the manufacturer's instructions and the requirements herein. A copy of this report and the installation instructions shall be provided at each job site by the manufacturer.
2. The product shall be used in well ventilated area.
3. Adjoining sheet edges shall overlap a minimum of 3".
4. All concrete surfaces shall be primed with Tremco Hot Rubber Primer at a rate of 300 to 500 square feet per gallon.
5. During construction, the membrane shall be covered by a dark color protective barrier where it is exposed to sunlight.

RR 25299  
Page 1 of 2

Tremco, Incorporated  
RE: Tremproof 6100 Membrane for below grade waterproofing

## **DISCUSSION**

The report is in compliance with the 2020 Los Angeles Building Code.

The approval is based on technical data and specifications submitted by the manufacturer and test data by a Los Angeles City approved testing agency.

The product can withstand hydrostatic pressure of 30 psi.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

---

QUAN NGHIEM, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone-213-482-0409  
QUAN.NGHIEM@LACITY.ORG

QN  
RR25299  
R10/11/2021  
TLB2100132  
1805.3